

ANNA M. ROTH, RN, MS, MPH
 HEALTH SERVICES DIRECTOR
 RANDALL L. SAWYER
 DEPUTY HEALTH DIRECTOR
 MATTHEW S. KAUFMANN
 ACTING DIRECTOR OF HAZARDOUS MATERIALS PROGRAMS



CONTRA COSTA
 HAZARDOUS
 MATERIALS PROGRAMS

4585 Pacheco Boulevard, Suite 100
 Martinez, California 94553
 Ph (925) 655-3200
 Fax (925) 646-2073
 ccchazmat@cchealth.org
 www.cchealth.org/hazmat/

COMPLAINT, INCIDENT, AND NOTIFICATION REPORT FORM

Type (Circle One): C I N

Received Date: 08/09/20 Received Time: 2:35 PM Received By: XB Lead: XB
 Incident Date: 8/09/20 Incident Time: 2:32 PM Assigned to: MPD Assigned Date: 8/9/20

CASE NUMBER: 200809 - 01

COMPLAINANT / REPORTING PARTY:

Name: _____ RP is from Facility Anonymous
 Organization: CCCFPD Cal OES # (if applicable) 20-4249
 Primary Phone Number: _____ Secondary Phone Number: _____
 Email: _____
 Address: _____
 City: _____ State: _____ Zip Code: _____

FACILITY / LOCATION OF INCIDENT:

Name: SOCIAL BIRD KITCHEN AND BAR CUPA Facility I.D.: _____
 Phone Number: _____
 Address: 3593 MT DIABLO BLVD Unit: _____
 City: LAFAYETTE State: CA Zip Code: 94549
 Location Description: _____

INITIAL INCIDENT DESCRIPTION:

RP STATES THAT AN UNDETERMINED AMOUNT OF CARBON DIOXIDE (CO2) WAS RELEASED; UNKNOWN TANK SIZE.

INCIDENT TYPE / DESCRIPTION:

Community Warning System Level (Circle Highest Level): N/A 0 1 2 3

| FACILITY | ISO / MCAR | TRANSPORTATION | MISCELLANEOUS |
|--|---|--|--|
| <input type="checkbox"/> Fire or Explosion <input checked="" type="checkbox"/> Spill or Release <input type="checkbox"/> Startup or Shutdown <input type="checkbox"/> Flaring <input type="checkbox"/> Upset | <input type="checkbox"/> Fatality (one or more) <input type="checkbox"/> > 24 hrs. Hospital, 3 or more people <input type="checkbox"/> Flammable Vapor Cloud > 5,000 lbs. | <input type="checkbox"/> Tank Truck <input type="checkbox"/> Railroad <input type="checkbox"/> On Water <input type="checkbox"/> Pipeline <input type="checkbox"/> Fuel Tank | <input type="checkbox"/> Storm Drain/Creek <input type="checkbox"/> Drug Lab <input type="checkbox"/> Disposal/Abandonment <input type="checkbox"/> Odor Complaint <input type="checkbox"/> Other: |

Time Enroute to Scene: _____ Time Arrived On Scene: _____ Time Departed From Scene: _____

REFERRED TO OTHER AGENCY:



| | |
|--|---|
| DTSC STATE FUNDING (if applicable): CLU/ERER Number: | STORMWATER STATUS (if applicable): <input type="checkbox"/> Actual Discharge <input type="checkbox"/> Potential Discharge |
|--|---|

AGENCIES ON SCENE OR NOTIFIED:

| Agency Type | Agency | O/N | Contact Person | Phone Number | Case Number |
|-----------------|---------------------------------------|-----|------------------------|--------------|-------------|
| Fire Department | Contra Costa Fire Protection District | O | Captain J Palant (E15) | | 20081721 |
| Law Enforcement | Lafayette Police | O | | | |
| Air District | | | | | |
| State OES | | N | | | 20-4249 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

REPORT:

On August 9, 2010 @ 14:32, Contra Costa Fire Protection District (ConFire) notified Contra Costa Health HazMat Response Team that they were responding to a Carbon Dioxide (CO2) leak alarm at 3593 Mt Diablo Blvd., Lafayette CA.

At 14:45, Specialist MPD was dispatched to the scene to assist ConFire with the site hazard assessment. It was discovered that the carbon dioxide delivery system hosing was leaking from a loose fitting. The CO2 sensor was installed approximately one foot up from the floor. CO2 is heavier than air, this low position allows the sensor to detect a leak early, maximizing the danger warning response time. The CO2 sensor was reported to have detected a TWA of 9,000 ppm. Based on ConFire's atmospheric gas measurements oxygen was reported to be normal at 20.8 percent.

MPD observed the concentration of CO2 in the storage room measured at 0.11 percent (1100 ppm) of air by the CO2 detector. Measurably higher than the normal 0.04 percent (400 ppm) of air. Based on multiple lines of evidence including; atmospheric measurements of oxygen and the CO2 sensor readings, the CO2's oxygen displacement did not pose an asphyxiation risk. ConFire actively vented the storage room with electric fans. The CO2 supply company (NuCO2) and the beverage vendor (Coca Cola) responded. Coca Cola soaped the lines, found and repaired the fitting stopping the leak. Oxygen levels were remeasured and observed to still be normal. The CO2 alarm was adjudicated and the CO2 sensor returned to service.

Specialist MPD departed the scene at 17:30.

Additional Required Items: Bill of Lading, Request for Invoice, and Site Safety Plan

Report Prepared by: XB

Alexandra McMullen

From: Warning Center <Warning.Center@oes.ca.gov>
Sent: Sunday, August 09, 2020 4:13 PM
To: ccchazmat@hsd.cccounty.us
Subject: [EXTERNAL] Hazardous Materials Spill Report: Cal OES Control #:20-4249

Governor's Office of Emergency Services
Hazardous Materials Spill Report

DATE: 08/09/2020 | RECEIVED BY Cal OES: Josh Gleason | Cal OES
CNTRL #:20-4249

TIME: 1603 | RECEIVED BY OSPR: | NRC#:

1.a. PERSON NOTIFYING Cal OES

1. NAME: Kristofer Hanson | 2. AGENCY: Social Bird Kitchen
and Bar
3. PHONE #: 92529985828 | 4. EXT: | 5. PAGER #:

1.b. PERSON REPORTING SPILL (if different from above):

1. NAME: | 2. AGENCY:
3. PHONE #: | 4. EXT: | 5. PAGER #:

2. SUBSTANCE TYPE:

a. SUBSTANCE: / b.QTY: / Amount / Measure / c. TYPE / d. OTHER / e.
PIPELINE / f. Vessel Over => 300 tons
1. CO2 / = / Unknown / Lbs. / UNSPECIFIED / / No / No

2.

3.

g. DESCRIPTION: The reporting party states that they don't know how the
CO2 was released. Also states that they don't know the size or amount that was in the tank.

h. CONTAINED: Stopped | i. WATER INVOLVED: No
j. WATERWAY: | k. DRINKING WATER IMPACTED: No
l. KNOWN IMPACT: None

3.a. INCIDENT LOCATION: 3593 Mount Diablo Blvd

b. CITY: Lafayette | c. COUNTY: Contra Costa County | d. ZIP:
94549

4. INCIDENT DESCRIPTION:

a. DATE: 8/9/2020 | b. TIME(Military): 1130 | c. SITE:

Merchant/Business | d. CAUSE: Unknown e. INJURIES: No | f. FATALITY: No | g. EVACUATIONS: No | h.
CLEANUP BY: Unrecoverable
e. INJURIES #: | f. FATALS #: | g. EVACS #:

5. SUSPECTED RESPONSIBLE PARTY:

a. NAME: Kristofer Hanson | b. AGENCY: Social Bird Kitchen and Bar
c. PHONE#: 92529985828 | d. EXT:
e. MAIL ADDRESS: 3593 Mount Diablo Blvd
f. CITY: Lafayette | g. STATE: CA | h. ZIP: 94549

6. NOTIFICATION INFORMATION:

a. ON SCENE: Co Health, Fire Dept. | b. OTHER ON SCENE:
c. OTHER NOTIFIED:
d. ADMIN. AGENCY: Contra Costa County Health Services Department e. SEC. AGENCY:
f. ADDITIONAL COUNTY: g. ADMIN. AGENCY:
h. NOTIFICATION LIST: DOG Unit: | RWQCB Unit: 2

AA/CUPA, DTSC, RWQCB, US EPA, USFWS, AIR RESOURCES BD

CONFIDENTIAL REMARKS:

Created by Warning Center on 8/9/2020 4:03:17 PM Last
Modified by Warning Center on 8/9/2020 4:09:58 PM

California State Warning Center
Governor's Office Emergency Services
Phone: (916) 845-8911
Warning.Center@oes.ca.gov

Link to Spill Report:

<http://w3.calema.ca.gov/operational/mal haz.nsf/SpillAllDocs/2A424CC6BBCACA34882585BF007EA4EA?OpenDocument>