Anna M. Roth, RN, MS, MPH Health Services Director Randall L. Sawyer Chief Environmental Health & HazMat Officer



Contra Costa Hazardous Materials Programs

4585 Pacheco Boulevard, Suite 100 Martinez, California 94553

> Ph (925) 335-3200 Fax (925) 646-2073 ccchazmat@hsd.cccounty.us www.cchealth.org/hazmat/

COMPLAINT, INCIDENT, AND NOTIFICATION REPORT FORM

| Type (Circle One): C I N | | CASE NUMB | ER: 1906140 1 — | | | | | | |
|--|--|--|--------------------------------|--|--|--|--|--|--|
| Received Date; 06/14/19 | Received Time: 12:36 | d Time: 12:36 Received By: HW Lead: TAJ | | | | | | | |
| Incident Date: 06/14/19 | | | Assigned Date: | | | | | | |
| COMPLAINANT / REPORTING PARTY: | | | | | | | | | |
| Name: HANK DANELLO | | □ RP is fr | om Facility □ Anonymous | | | | | | |
| Organization: | | | | | | | | | |
| Primary Phone Number: (510) 813-2538 Secondary Phone Number: | | | | | | | | | |
| Email: | | | | | | | | | |
| Address: | | | | | | | | | |
| City: | | State: Zip Code: | | | | | | | |
| FACILITY / LOCATION OF INCIDENT: | | | | | | | | | |
| Name:CUPA Facility I.D.: | | | | | | | | | |
| Phone Number: | | | | | | | | | |
| Address: DOWRELIO DR Unit: | | | | | | | | | |
| City: CROCKETT | | State: CA Zip Code: 94525 | | | | | | | |
| Location Description: SID | E OF ROAD | | | | | | | | |
| INITIAL INCIDENT DESCRIP | TION: | *************************************** | | | | | | | |
| Complainant observed a rusty 55-gallon drum on its side, hidden in the brush. Contents smelled like oil and is possibly weeping. | | | | | | | | | |
| INCIDENT TYPE / DESCRIPTION: | | | | | | | | | |
| Gommunity Warning System Level (Circle Highest Level): N/A 0 1 2 3 | | | | | | | | | |
| FACILITY | ISO / MCAR | TRANSPORTATION | MISCELLANEOUS | | | | | | |
| ☐ Fire or Explosion☐ Spill or Release | □ Fatality (one or more)□ > 24 hrs. Hospital, 3 or | □ Tank.Truck □ Railroad | ☐ Storm Drain/Creek ☐ Drug Lab | | | | | | |
| □ Startup or Shutdown | more people | □ On Water | Disposal/Abandonment | | | | | | |
| □ Flaring □ Upset | □ Flammable Vapor Cloud > 5,000 lbs. | □ Pipeline □ Fuel Tank | ☐ Odor Complaint☐ Other: | | | | | | |
| Time Enroute to Scene: | Time Arrived On Scen | Time Arrived On Scene: Time Departed From Scene: | | | | | | | |
| REFERRED TO OTHER AGENCY: | | | | | | | | | |
| | | | | | | | | | |



- Contra Costa Behavioral Health Services Contra Costa Emergency Medical Services Contra Costa Environmental Health & Hazardous Materials Programs •
- Contra Costa Health, Housing & Homeless Services Contra Costa Health Plan Contra Costa Public Health Contra Costa Regional Medical Center & Health Centers •

| DTSC STATE FUNDING (if applicable): | STORMWATER STATUS (if a | pplicable): |
|-------------------------------------|-------------------------|-----------------------|
| CLU/ERER Number: | □ Actual Discharge | □ Potential Discharge |

AGENCIES ON SCENE OR NOTIFIED:

| Agency Type | Agency | <u>O/N</u> | Contact Person | Phone Number | Case Number |
|-----------------|--------|------------|----------------|--------------|-------------|
| Fire Department | | | | | |
| Law Enforcement | | | | | |
| Air District | | | | | |
| State OES | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

REPORT:

6/14/2019: The complaint was called in directly to CCHSHMP by Michele Mancuso of the County Watershed Program. She provided to me the complainant's contact information. I spoke with complainant Mr. Hank Danello to get more clear direction to access the location of the abandoned drum. He offered to meet up with the responding team members if there was any difficulty in locating the drum. I dispatched HMS 1202 (M. Duazo) and 1218 (K. Abramians) to investigate the complaint.

Duazo and Abramians had initial difficulty finding the drum. Ipr ovided the details told to me by Mr. Danello regarding location, such as the drum being across the way from the water treatment plant and checking out the brush on the left side of the road after the second speed bump. The team was able to locate the drum, which was really hidden in the brush (see photo), as described by the complainant, and in a damp marsh-like area. The drum was found on its side. Prior to working on recovering the drum, the team did conduct a tailgate safety meeting. The team uprighted the drum and brought it back to the office.

The team brought a closer look at the drum. Duazo and Abramians wanted to confer with me that the drum was not leaking or weeping, as originally reported. The dampness may be attributed to the environment it was in at the time of discovery. The drum was rusty and did not look to be in the best condition. A faded label was legible enough to read that the drum may have originally been from Hensley St. in Richmond and given the condition of the drum, is quite old. The label read that the drum contained red-dyed diesel, which the team confirmed. The dye of the fuel, however, is now an orange color, as opposed to, the original red; again, lending to possibly of the old age of the drum.

רים (מים ביים) The team affixed a hazardous waste label with all of the proper information on the it.

Additional Required Items: Bill of Lading, Request for Invoice, and Site Safety Plan

Trisha A. Johnson 6/14/2019

Report Prepared by:

Rev. April 2018