

ENVIRONMENTAL HEALTH DIVISION

2120 Diamond Blvd., Suite 200 Concord, CA 94520 Phone: (925) 692-2500

Fax: (925) 692-2505 www.cchealth.org/eh/

POOL ENCLOSURE REQUIREMENTS

California Code of Regulations, Title 24, Section 3119B

Section 3119B.1 Enclosure. The pool shall be enclosed by one or a combination of the following: a fence; portion of a building; wall; or other approved durable enclosure. Doors, windows, gates of living units or associated private premises, shall not be permitted as part of the pool enclosure. The enclosure, doors, and gates shall meet all of the following specifications:

- 1. The enclosure shall have a minimum effective perpendicular height of **5 feet** as measured from the outside as depicted in Figure 31B-4.
- 2. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch diameter sphere. The enclosure shall be constructed over a hard and permanent material equivalent to concrete.
- 3. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children. Horizontal and diagonal member designs which might serve as a ladder for small children are prohibited. Horizontal members shall be spaced at least 48-inches apart. No planters or structures that can be climbed shall be permitted within 5 feet of the outside of the pool enclosure or within a 5 foot arch as depicted on Figure 31B-5. The area 5 feet outside of the pool enclosure shall be a common area open to the public.
- 4. Chained linked may be used, provided that the openings are **not greater than 1** ³/₄**-inches** measured horizontally.

Section 3119B.2 Gates. Gates and doors opening into the pool enclosure also shall meet the following specifications:

- 1. Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by a law. Hand activated door or gate opening hardware shall be located at a height no lower than 42-inches but no higher than 44-inches above the deck or walkway.
- Gates and doors shall be capable of being locked during times when the pool is closed. Exit doors which comply with Chapter 10, Title 24, California Code of Regulations shall be considered as meeting these requirements.
- 3. The pool enclosure shall have at least one means of egress without a key for emergency purposes. Unless all gates or doors are so equipped, those gates and/or doors which will allow egress without a key shall have a sign in letters at least 4-inches high stating **EMERGENCY EXIT.**
- 4. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or walkway accessible by all patrons of the pool.




Figure 31B-4
PERPENDICULAR FENCING DIMENSIONS ON SLOPING GROUND




Figure 31B-5
EFFECTIVE FENCING HEIGHT